

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF COOL WATERWORKS,)	
INC. FOR A DEVIATION FROM 807 KAR 5:066,)	CASE NO. 94-296
SECTION 4(4), REGARDING WATER STORAGE)	

O R D E R

By application received August 9, 1994, Cool Waterworks, Inc. ("Cool Waterworks") requested a deviation from Commission Regulation 807 KAR 5:066, Section 4(4), which requires that each utility shall provide water storage to ensure a minimum of one day's supply of its average daily water usage. Cool Waterworks states that its average daily water usage, including unaccounted-for water, is approximately 13,400 gallons, and that its current water storage capacity is 2,250 gallons.

The Commission, having reviewed the application and being otherwise sufficiently advised, finds that:

1. Cool Waterworks is not in compliance with Commission Regulation 807 KAR 5:066, Section 4(4).

2. Because of the time needed to plan, finance, and implement a program to construct water storage facilities, Cool Waterworks should be given until January 1, 2000 to comply with 807 KAR 5:066, Section 4(4).

IT IS THEREFORE ORDERED that:

1. Cool Waterworks be and it hereby is given until January 1, 2000 to comply with the provisions of 807 KAR 5:066, Section 4(4).

2. Cool Waterworks shall take all necessary actions to bring its water storage facilities into compliance with Commission regulations prior to January 1, 2000.

Done at Frankfort, Kentucky, this 3rd day of October, 1994.

PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman


Commissioner

ATTEST:


Executive Director